

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 24)**

Water Level of the accumulated water (at 16:00 on October 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,332 mm (20 mm increase since 7:00 on October 24)	O.P.+ 3,101 mm (7 mm increase since 7:00 on October 24)	—
	Water level of Turbine Building	O.P.+ 2,933 mm (9 mm increase since 7:00 on October 24)	O.P.+ 3,336 mm (20 mm increase since 7:00 on October 24)	O.P.+ 3,033 mm (14 mm increase since 7:00 on October 24)	O.P.+ 3,011 mm (1 mm decrease since 7:00 on October 24)
	Water level of Reactor Building	O.P.+ 4,632 mm (6 mm increase since 7:00 on October 24)	O.P.+ 3,571 mm (17 mm increase since 7:00 on October 24)	O.P.+ 3,187 mm (8 mm increase since 7:00 on October 24)	O.P.+ 3,014 mm (1 mm increase since 7:00 on October 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,814 mm (Increase from initial level:6,031 mm, 1 mm increase since 7:00 on October 24) O.P.+ 2,221 mm (Increase from initial level:2,947 mm, 209 mm decrease since 7:00 on October 24) O.P.+ 4,237 mm (Water level from floor:441 mm, No change since 7:00 on October 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 15:44 on October 24)	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:02 on October 24)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:21 on October 18   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.