

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 25)**

Water Level of the accumulated water (at 7:00 on October 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,286 mm (46 mm decrease since 16:00 on October 24)	O.P.+ 3,136 mm (35 mm increase since 16:00 on October 24)	—
	Water level of Turbine Building	O.P.+ 2,949 mm (16 mm increase since 16:00 on October 24)	O.P.+ 3,295 mm (41 mm decrease since 16:00 on October 24)	O.P.+ 3,103 mm (70 mm increase since 16:00 on October 24)	O.P.+ 2,979 mm (32 mm decrease since 16:00 on October 24)
	Water level of Reactor Building	O.P.+ 4,635 mm (3 mm increase since 16:00 on October 24)	O.P.+ 3,545 mm (26 mm decrease since 16:00 on October 24)	O.P.+ 3,256 mm (69 mm increase since 16:00 on October 24)	O.P.+ 2,987 mm (27 mm decrease since 16:00 on October 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,815 mm (Increase from initial level:6,032 mm, 1 mm increase since 16:00 on October 24) O.P.+ 2,132 mm (Increase from initial level:2,858 mm, 89 mm decrease since 16:00 on October 24) O.P.+ 4,238 mm (Water level from floor:442 mm, 1 mm increase since 16:00 on October 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 15:44 on October 24)	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:02 on October 24)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:36 on October 25 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 8:36 AM on October 25, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

For quick publication of the data of water level, values are provided as reference values.