

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on October 26)**

Water Level of the accumulated water (at 7:00 on October 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,230 mm (34 mm decrease since 16:00 on October 25)	O.P.+ 3,206 mm (45 mm increase since 16:00 on October 25)	—
	Water level of Turbine Building	O.P.+ 2,974 mm (16 mm increase since 16:00 on October 25)	O.P.+ 3,245 mm (29 mm decrease since 16:00 on October 25)	O.P.+ 3,187 mm (53 mm increase since 16:00 on October 25)	O.P.+ 2,943 mm (20 mm decrease since 16:00 on October 25)
	Water level of Reactor Building	O.P.+ 4,618 mm (14 mm decrease since 16:00 on October 25)	O.P.+ 3,489 mm (38 mm decrease since 16:00 on October 25)	O.P.+ 3,345 mm (52 mm increase since 16:00 on October 25)	O.P.+ 2,952 mm (21 mm decrease since 16:00 on October 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,818 mm (Increase from initial level:6,035 mm, 2 mm increase since 16:00 on October 25) O.P.+ 2,183 mm (Increase from initial level:2,909 mm, 93 mm decrease since 16:00 on October 25) O.P.+ 4,239 mm (Water level from floor:443 mm, 1 mm increase since 16:00 on October 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 15:44 on October 24)	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:02 on October 24)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:04 on October 25 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.