

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 26)**

Water Level of the accumulated water (at 16:00 on October 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,210 mm (20 mm decrease since 7:00 on October 26)	O.P.+ 3,222 mm (16 mm increase since 7:00 on October 26)	—
	Water level of Turbine Building	O.P.+ 2,982 mm (8 mm increase since 7:00 on October 26)	O.P.+ 3,227 mm (18 mm decrease since 7:00 on October 26)	O.P.+ 3,193 mm (6 mm increase since 7:00 on October 26)	O.P.+ 2,931 mm (12 mm decrease since 7:00 on October 26)
	Water level of Reactor Building	O.P.+ 4,607 mm (11 mm decrease since 7:00 on October 26)	O.P.+ 3,474 mm (15 mm decrease since 7:00 on October 26)	O.P.+ 3,359 mm (14 mm increase since 7:00 on October 26)	O.P.+ 2,942 mm (10 mm decrease since 7:00 on October 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,818 mm (Increase from initial level:6,035 mm, No change since 7:00 on October 26) O.P.+ 2,239 mm (Increase from initial level:2,965 mm, 56 mm increase since 7:00 on October 26) O.P.+ 4,240 mm (Water level from floor:444 mm, 1 mm increase since 7:00 on October 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 15:44 on October 24)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:18 on October 26)	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:02 on October 24)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:04 on October 25   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.