

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 30)**

Water Level of the accumulated water (at 16:00 on October 30)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,374 mm (11 mm decrease since 7:00 on October 30)	O.P.+ 2,976 mm (5 mm decrease since 7:00 on October 30)	—
	Water level of Turbine Building	O.P.+ 3,076 mm (9 mm increase since 7:00 on October 30)	O.P.+ 3,372 mm (8 mm decrease since 7:00 on October 30)	O.P.+ 2,901 mm (1 mm increase since 7:00 on October 30)	O.P.+ 2,871 mm (8 mm increase since 7:00 on October 30)
	Water level of Reactor Building	O.P.+ 4,679 mm (17 mm increase since 7:00 on October 30)	O.P.+ 3,621 mm (4 mm increase since 7:00 on October 30)	O.P.+ 3,054 mm (10 mm decrease since 7:00 on October 30)	O.P.+ 2,879 mm (9 mm increase since 7:00 on October 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,828 mm (Increase from initial level:6,045 mm, No change since 7:00 on October 30) O.P.+ 3,367 mm (Increase from initial level:4,093 mm, 66 mm decrease since 7:00 on October 30) O.P.+ 4,246 mm (Water level from floor:450 mm, No change since 7:00 on October 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:09 on October 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:18 on October 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:04 on October 25   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.