

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on October 31)**

Water Level of the accumulated water (at 16:00 on October 31)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,313 mm (21 mm decrease since 7:00 on October 31)	O.P.+ 3,004 mm (11 mm increase since 7:00 on October 31)	—
	Water level of Turbine Building	O.P.+ 3,103 mm (13 mm increase since 7:00 on October 31)	O.P.+ 3,318 mm (18 mm decrease since 7:00 on October 31)	O.P.+ 2,929 mm (12 mm increase since 7:00 on October 31)	O.P.+ 2,891 mm (7 mm increase since 7:00 on October 31)
	Water level of Reactor Building	O.P.+ 4,703 mm (5 mm increase since 7:00 on October 31)	O.P.+ 3,569 mm (19 mm decrease since 7:00 on October 31)	O.P.+ 3,083 mm (12 mm increase since 7:00 on October 31)	O.P.+ 2,899 mm (8 mm increase since 7:00 on October 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,830 mm (Increase from initial level:6,047 mm, 1 mm increase since 7:00 on October 31) O.P.+ 3,189 mm (Increase from initial level:3,915 mm, 65 mm decrease since 7:00 on October 31) O.P.+ 4,246 mm (Water level from floor:450 mm, No change since 7:00 on October 31)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:09 on October 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:18 on October 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:04 on October 25 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.