

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 1)**

Water Level of the accumulated water (at 7:00 on November 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,279 mm (34 mm decrease since 16:00 on October 31)	O.P.+ 3,017 mm (13 mm increase since 16:00 on October 31)	—
	Water level of Turbine Building	O.P.+ 3,117 mm (14 mm increase since 16:00 on October 31)	O.P.+ 3,288 mm (30 mm decrease since 16:00 on October 31)	O.P.+ 2,944 mm (15 mm increase since 16:00 on October 31)	O.P.+ 2,906 mm (15 mm increase since 16:00 on October 31)
	Water level of Reactor Building	O.P.+ 4,703 mm (No change since 16:00 on October 31)	O.P.+ 3,540 mm (29 mm decrease since 16:00 on October 31)	O.P.+ 3,097 mm (14 mm increase since 16:00 on October 31)	O.P.+ 2,910 mm (11 mm increase since 16:00 on October 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,832 mm (Increase from initial level:6,049 mm, 2 mm increase since 16:00 on October 31) O.P.+ 3,086 mm (Increase from initial level:3,812 mm, 103 mm decrease since 16:00 on October 31) O.P.+ 4,247 mm (Water level from floor:451 mm, 1 mm increase since 16:00 on October 31)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:09 on October 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:18 on October 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:39 on November 1   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	– At 7:39 AM on November 1, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.