

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 2)**

Water Level of the accumulated water (at 7:00 on November 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,226 mm (35 mm decrease since 16:00 on November 1)	O.P.+ 3,038 mm (13 mm increase since 16:00 on November 1)	—
	Water level of Turbine Building	O.P.+ 3,139 mm (13 mm increase since 16:00 on November 1)	O.P.+ 3,242 mm (28 mm decrease since 16:00 on November 1)	O.P.+ 2,966 mm (14 mm increase since 16:00 on November 1)	O.P.+ 2,926 mm (13 mm increase since 16:00 on November 1)
	Water level of Reactor Building	O.P.+ 4,684 mm (15 mm decrease since 16:00 on November 1)	O.P.+ 3,495 mm (30 mm decrease since 16:00 on November 1)	O.P.+ 3,121 mm (13 mm increase since 16:00 on November 1)	O.P.+ 2,927 mm (9 mm increase since 16:00 on November 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,835 mm (Increase from initial level:6,052 mm, 2 mm increase since 16:00 on November 1) O.P.+ 3,397 mm (Increase from initial level:4,123 mm, 54 mm decrease since 16:00 on November 1) O.P.+ 4,248 mm (Water level from floor:452 mm, No change since 16:00 on November 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:09 on October 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:18 on October 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 19:40 on November 1 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 7:39 AM on November 1, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 6:34 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 7:40 PM on the same day.				

For quick publication of the data of water level, values are provided as reference values.