

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 5)**

Water Level of the accumulated water (at 16:00 on November 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,230 mm (21 mm decrease since 7:00 on November 5)	O.P.+ 3,065 mm (9 mm increase since 7:00 on November 5)	—
	Water level of Turbine Building	O.P.+ 2,778 mm (8 mm increase since 7:00 on November 5)	O.P.+ 3,244 mm (18 mm decrease since 7:00 on November 5)	O.P.+ 2,987 mm (7 mm increase since 7:00 on November 5)	O.P.+ 2,953 mm (8 mm increase since 7:00 on November 5)
	Water level of Reactor Building	O.P.+ 4,584 mm (13 mm decrease since 7:00 on November 5)	O.P.+ 3,500 mm (17 mm decrease since 7:00 on November 5)	O.P.+ 3,146 mm (8 mm increase since 7:00 on November 5)	O.P.+ 2,955 mm (6 mm increase since 7:00 on November 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,841 mm (Increase from initial level:6,058 mm, No change since 7:00 on November 5) O.P.+ 2,534 mm (Increase from initial level:3,260 mm, 63 mm decrease since 7:00 on November 5) O.P.+ 4,251 mm (Water level from floor:455 mm, No change since 7:00 on November 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:14 on November 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:17 on November 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 19:40 on November 1 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.