

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 6)**

Water Level of the accumulated water (at 7:00 on November 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,195 mm (35 mm decrease since 16:00 on November 5)	O.P.+ 3,077 mm (12 mm increase since 16:00 on November 5)	—
	Water level of Turbine Building	O.P.+ 2,791 mm (13 mm increase since 16:00 on November 5)	O.P.+ 3,214 mm (30 mm decrease since 16:00 on November 5)	O.P.+ 3,001 mm (14 mm increase since 16:00 on November 5)	O.P.+ 2,962 mm (9 mm increase since 16:00 on November 5)
	Water level of Reactor Building	O.P.+ 4,561 mm (23 mm decrease since 16:00 on November 5)	O.P.+ 3,472 mm (28 mm decrease since 16:00 on November 5)	O.P.+ 3,161 mm (15 mm increase since 16:00 on November 5)	O.P.+ 2,964 mm (9 mm increase since 16:00 on November 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,843 mm (Increase from initial level:6,060 mm, 2 mm increase since 16:00 on November 5) O.P.+ 2,425 mm (Increase from initial level:3,151 mm, 109 mm decrease since 16:00 on November 5) O.P.+ 4,252 mm (Water level from floor:456 mm, 1 mm increase since 16:00 on November 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:14 on November 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:17 on November 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 19:40 on November 1 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.