

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 6)**

Water Level of the accumulated water (at 16:00 on November 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,175 mm (20 mm decrease since 7:00 on November 6)	O.P.+ 3,084 mm (7 mm increase since 7:00 on November 6)	—
	Water level of Turbine Building	O.P.+ 2,799 mm (8 mm increase since 7:00 on November 6)	O.P.+ 3,197 mm (17 mm decrease since 7:00 on November 6)	O.P.+ 3,010 mm (9 mm increase since 7:00 on November 6)	O.P.+ 2,969 mm (7 mm increase since 7:00 on November 6)
	Water level of Reactor Building	O.P.+ 4,555 mm (6 mm decrease since 7:00 on November 6)	O.P.+ 3,458 mm (14 mm decrease since 7:00 on November 6)	O.P.+ 3,171 mm (10 mm increase since 7:00 on November 6)	O.P.+ 2,970 mm (6 mm increase since 7:00 on November 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,843 mm (Increase from initial level:6,060 mm, No change since 7:00 on November 6) O.P.+ 2,363 mm (Increase from initial level:3,089 mm, 62 mm decrease since 7:00 on November 6) O.P.+ 4,253 mm (Water level from floor:457 mm, 1 mm increase since 7:00 on November 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:14 on November 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:17 on November 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 19:40 on November 1   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.