

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 7)**

Water Level of the accumulated water (at 7:00 on November 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,147 mm (28 mm decrease since 16:00 on November 6)	O.P.+ 3,097 mm (13 mm increase since 16:00 on November 6)	—
	Water level of Turbine Building	O.P.+ 2,813 mm (14 mm increase since 16:00 on November 6)	O.P.+ 3,171 mm (26 mm decrease since 16:00 on November 6)	O.P.+ 3,023 mm (13 mm increase since 16:00 on November 6)	O.P.+ 2,980 mm (11 mm increase since 16:00 on November 6)
	Water level of Reactor Building	O.P.+ 4,549 mm (6 mm decrease since 16:00 on November 6)	O.P.+ 3,433 mm (25 mm decrease since 16:00 on November 6)	O.P.+ 3,184 mm (13 mm increase since 16:00 on November 6)	O.P.+ 2,980 mm (10 mm increase since 16:00 on November 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,846 mm (Increase from initial level:6,063 mm, 3 mm increase since 16:00 on November 6) O.P.+ 2,258 mm (Increase from initial level:2,984 mm, 105 mm decrease since 16:00 on November 6) O.P.+ 4,254 mm (Water level from floor:458 mm, 1 mm increase since 16:00 on November 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:14 on November 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:17 on November 2)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 19:40 on November 1 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.