

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 9)**

Water Level of the accumulated water (at 7:00 on November 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,171 mm (49 mm increase since 16:00 on November 8)	O.P.+ 3,090 mm (20 mm decrease since 16:00 on November 8)	—
	Water level of Turbine Building	O.P.+ 2,851 mm (11 mm increase since 16:00 on November 8)	O.P.+ 3,190 mm (42 mm increase since 16:00 on November 8)	O.P.+ 2,993 mm (39 mm decrease since 16:00 on November 8)	O.P.+ 2,999 mm (5 mm decrease since 16:00 on November 8)
	Water level of Reactor Building	O.P.+ 4,487 mm (20 mm decrease since 16:00 on November 8)	O.P.+ 3,433 mm (41 mm increase since 16:00 on November 8)	O.P.+ 3,160 mm (42 mm decrease since 16:00 on November 8)	O.P.+ 3,003 mm (3 mm increase since 16:00 on November 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,789 mm (Increase from initial level:6,006 mm, 54 mm decrease since 16:00 on November 8) O.P.+ 2,242 mm (Increase from initial level:2,968 mm, 49 mm increase since 16:00 on November 8) O.P.+ 4,254 mm (Water level from floor:458 mm, No change since 16:00 on November 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 12:31 on November 8)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:50 on November 8   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.