

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 9)**

Water Level of the accumulated water (at 16:00 on November 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,197 mm (26 mm increase since 7:00 on November 9)	O.P.+ 3,080 mm (10 mm decrease since 7:00 on November 9)	—
	Water level of Turbine Building	O.P.+ 2,856 mm (5 mm increase since 7:00 on November 9)	O.P.+ 3,214 mm (24 mm increase since 7:00 on November 9)	O.P.+ 2,977 mm (16 mm decrease since 7:00 on November 9)	O.P.+ 2,992 mm (7 mm decrease since 7:00 on November 9)
	Water level of Reactor Building	O.P.+ 4,481 mm (6 mm decrease since 7:00 on November 9)	O.P.+ 3,454 mm (21 mm increase since 7:00 on November 9)	O.P.+ 3,142 mm (18 mm decrease since 7:00 on November 9)	O.P.+ 2,993 mm (10 mm decrease since 7:00 on November 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,758 mm (Increase from initial level:5,975 mm, 31 mm decrease since 7:00 on November 9) O.P.+ 2,271 mm (Increase from initial level:2,997 mm, 29 mm increase since 7:00 on November 9) O.P.+ 4,255 mm (Water level from floor:459 mm, 1 mm increase since 7:00 on November 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 12:31 on November 8)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:50 on November 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.