

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 12)**

Water Level of the accumulated water (at 7:00 on November 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,243 mm (43 mm decrease since 16:00 on November 11)	O.P.+ 3,047 mm (14 mm increase since 16:00 on November 11)	—
	Water level of Turbine Building	O.P.+ 2,897 mm (11 mm increase since 16:00 on November 11)	O.P.+ 3,253 mm (38 mm decrease since 16:00 on November 11)	O.P.+ 2,964 mm (29 mm increase since 16:00 on November 11)	O.P.+ 2,943 mm (2 mm increase since 16:00 on November 11)
	Water level of Reactor Building	O.P.+ 4,489 mm (8 mm increase since 16:00 on November 11)	O.P.+ 3,519 mm (28 mm decrease since 16:00 on November 11)	O.P.+ 3,123 mm (32 mm increase since 16:00 on November 11)	O.P.+ 2,946 mm (1 mm decrease since 16:00 on November 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,545 mm (Increase from initial level:5,762 mm, 58 mm decrease since 16:00 on November 11) O.P.+ 2,469 mm (Increase from initial level:3,195 mm, 46 mm increase since 16:00 on November 11) O.P.+ 4,257 mm (Water level from floor:461 mm, 1 mm increase since 16:00 on November 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:05 on November 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 12:31 on November 8)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:50 on November 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.