

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 12)**

Water Level of the accumulated water (at 16:00 on November 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,220 mm (23 mm decrease since 7:00 on November 12)	O.P.+ 3,059 mm (12 mm increase since 7:00 on November 12)	—
	Water level of Turbine Building	O.P.+ 2,902 mm (5 mm increase since 7:00 on November 12)	O.P.+ 3,236 mm (17 mm decrease since 7:00 on November 12)	O.P.+ 2,974 mm (10 mm increase since 7:00 on November 12)	O.P.+ 2,948 mm (5 mm increase since 7:00 on November 12)
	Water level of Reactor Building	O.P.+ 4,501 mm (12 mm increase since 7:00 on November 12)	O.P.+ 3,504 mm (15 mm decrease since 7:00 on November 12)	O.P.+ 3,137 mm (14 mm increase since 7:00 on November 12)	O.P.+ 2,950 mm (4 mm increase since 7:00 on November 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,573 mm (Increase from initial level:5,790 mm, 28 mm increase since 7:00 on November 12) O.P.+ 2,541 mm (Increase from initial level:3,267 mm, 72 mm increase since 7:00 on November 12) O.P.+ 4,257 mm (Water level from floor:461 mm, No change since 7:00 on November 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:05 on November 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 12:31 on November 8)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:25 on November 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 12:54 PM on November 12, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 5:05 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 5:25 PM on the same day.				

For quick publication of the data of water level, values are provided as reference values.