

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 13)**

Water Level of the accumulated water (at 7:00 on November 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,190 mm (30 mm decrease since 16:00 on November 12)	O.P.+ 3,072 mm (13 mm increase since 16:00 on November 12)	—
	Water level of Turbine Building	O.P.+ 2,913 mm (11 mm increase since 16:00 on November 12)	O.P.+ 3,206 mm (30 mm decrease since 16:00 on November 12)	O.P.+ 2,988 mm (14 mm increase since 16:00 on November 12)	O.P.+ 2,956 mm (8 mm increase since 16:00 on November 12)
	Water level of Reactor Building	O.P.+ 4,514 mm (13 mm increase since 16:00 on November 12)	O.P.+ 3,471 mm (33 mm decrease since 16:00 on November 12)	O.P.+ 3,153 mm (16 mm increase since 16:00 on November 12)	O.P.+ 2,959 mm (9 mm increase since 16:00 on November 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,504 mm (Increase from initial level:5,721 mm, 69 mm decrease since 16:00 on November 12) O.P.+ 2,588 mm (Increase from initial level:3,314 mm, 47 mm increase since 16:00 on November 12) O.P.+ 4,257 mm (Water level from floor:461 mm, No change since 16:00 on November 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:05 on November 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 12:31 on November 8)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:25 on November 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.