

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 13)**

Water Level of the accumulated water (at 16:00 on November 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,171 mm (19 mm decrease since 7:00 on November 13)	O.P.+ 3,079 mm (7 mm increase since 7:00 on November 13)	—
	Water level of Turbine Building	O.P.+ 2,920 mm (7 mm increase since 7:00 on November 13)	O.P.+ 3,189 mm (17 mm decrease since 7:00 on November 13)	O.P.+ 2,996 mm (8 mm increase since 7:00 on November 13)	O.P.+ 2,962 mm (6 mm increase since 7:00 on November 13)
	Water level of Reactor Building	O.P.+ 4,516 mm (2 mm increase since 7:00 on November 13)	O.P.+ 3,454 mm (17 mm decrease since 7:00 on November 13)	O.P.+ 3,161 mm (8 mm increase since 7:00 on November 13)	O.P.+ 2,965 mm (6 mm increase since 7:00 on November 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,451 mm (Increase from initial level:5,668 mm, 53 mm decrease since 7:00 on November 13) O.P.+ 2,619 mm (Increase from initial level:3,345 mm, 31 mm increase since 7:00 on November 13) O.P.+ 4,257 mm (Water level from floor:461 mm, No change since 7:00 on November 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:05 on November 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 12:31 on November 8)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:25 on November 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.