

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 14)**

Water Level of the accumulated water (at 7:00 on November 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,138 mm (33 mm decrease since 16:00 on November 13)	O.P.+ 3,089 mm (10 mm increase since 16:00 on November 13)	—
	Water level of Turbine Building	O.P.+ 2,930 mm (10 mm increase since 16:00 on November 13)	O.P.+ 3,161 mm (28 mm decrease since 16:00 on November 13)	O.P.+ 3,008 mm (12 mm increase since 16:00 on November 13)	O.P.+ 2,971 mm (9 mm increase since 16:00 on November 13)
	Water level of Reactor Building	O.P.+ 4,515 mm (1 mm decrease since 16:00 on November 13)	O.P.+ 3,427 mm (27 mm decrease since 16:00 on November 13)	O.P.+ 3,174 mm (13 mm increase since 16:00 on November 13)	O.P.+ 2,973 mm (8 mm increase since 16:00 on November 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,362 mm (Increase from initial level:5,579 mm, 89 mm decrease since 16:00 on November 13) O.P.+ 2,664 mm (Increase from initial level:3,390 mm, 45 mm increase since 16:00 on November 13) O.P.+ 4,257 mm (Water level from floor:461 mm, No change since 16:00 on November 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:05 on November 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 12:31 on November 8)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:25 on November 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.