

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 14)**

Water Level of the accumulated water (at 16:00 on November 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,119 mm (19 mm decrease since 7:00 on November 14)	O.P.+ 3,097 mm (8 mm increase since 7:00 on November 14)	—
	Water level of Turbine Building	O.P.+ 2,938 mm (8 mm increase since 7:00 on November 14)	O.P.+ 3,144 mm (17 mm decrease since 7:00 on November 14)	O.P.+ 3,015 mm (7 mm increase since 7:00 on November 14)	O.P.+ 2,977 mm (6 mm increase since 7:00 on November 14)
	Water level of Reactor Building	O.P.+ 4,511 mm (4 mm decrease since 7:00 on November 14)	O.P.+ 3,411 mm (16 mm decrease since 7:00 on November 14)	O.P.+ 3,180 mm (6 mm increase since 7:00 on November 14)	O.P.+ 2,979 mm (6 mm increase since 7:00 on November 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,310 mm (Increase from initial level:5,527 mm, 52 mm decrease since 7:00 on November 14) O.P.+ 2,695 mm (Increase from initial level:3,421 mm, 31 mm increase since 7:00 on November 14) O.P.+ 4,257 mm (Water level from floor:461 mm, No change since 7:00 on November 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:05 on November 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 12:31 on November 8)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:25 on November 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.