

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 15)**

Water Level of the accumulated water (at 7:00 on November 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,086 mm (33 mm decrease since 16:00 on November 14)	O.P.+ 3,106 mm (9 mm increase since 16:00 on November 14)	—
	Water level of Turbine Building	O.P.+ 2,947 mm (9 mm increase since 16:00 on November 14)	O.P.+ 3,115 mm (29 mm decrease since 16:00 on November 14)	O.P.+ 3,025 mm (10 mm increase since 16:00 on November 14)	O.P.+ 2,987 mm (10 mm increase since 16:00 on November 14)
	Water level of Reactor Building	O.P.+ 4,495 mm (16 mm decrease since 16:00 on November 14)	O.P.+ 3,381 mm (30 mm decrease since 16:00 on November 14)	O.P.+ 3,192 mm (12 mm increase since 16:00 on November 14)	O.P.+ 2,987 mm (8 mm increase since 16:00 on November 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,223 mm (Increase from initial level:5,440 mm, 87 mm decrease since 16:00 on November 14) O.P.+ 2,740 mm (Increase from initial level:3,466 mm, 45 mm increase since 16:00 on November 14) O.P.+ 4,257 mm (Water level from floor:461 mm, No change since 16:00 on November 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:05 on November 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 12:31 on November 8)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:28 on November 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:28 AM on November 15, the second cesium absorption apparatus (SARRY) was temporarily stopped for filter cleaning.				

For quick publication of the data of water level, values are provided as reference values.