

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 15)

Water Level of the accumulated water (at 16:00 on November 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,066 mm (20 mm decrease since 7:00 on November 15)	O.P.+ 3,115 mm (9 mm increase since 7:00 on November 15)	—
	Water level of Turbine Building	O.P.+ 2,953 mm (6 mm increase since 7:00 on November 15)	O.P.+ 3,097 mm (18 mm decrease since 7:00 on November 15)	O.P.+ 3,033 mm (8 mm increase since 7:00 on November 15)	O.P.+ 2,992 mm (5 mm increase since 7:00 on November 15)
	Water level of Reactor Building	O.P.+ 4,482 mm (13 mm decrease since 7:00 on November 15)	O.P.+ 3,364 mm (17 mm decrease since 7:00 on November 15)	O.P.+ 3,201 mm (9 mm increase since 7:00 on November 15)	O.P.+ 2,993 mm (6 mm increase since 7:00 on November 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,246 mm (Increase from initial level:5,463 mm, 23 mm increase since 7:00 on November 15) O.P.+ 2,766 mm (Increase from initial level:3,492 mm, 26 mm increase since 7:00 on November 15) O.P.+ 4,257 mm (Water level from floor:461 mm, No change since 7:00 on November 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3 ^{*1}	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:05 on November 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:18 on November 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:40 on November 15 In operation ^{*2} Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*1 From 12:31 PM on November 2 to 10:02 on November 15, transfer of the accumulated water from Unit 3 Turbine Building basement to the Central Radioactive Waste Treatment Facility (Process Main Building) was conducted. *2 At 8:28 AM on November 15, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 11:13 AM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 11:40 AM on the same day.				

For quick publication of the data of water level, values are provided as reference values.