

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 16)**

Water Level of the accumulated water (at 7:00 on November 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,032 mm (34 mm decrease since 16:00 on November 15)	O.P.+ 3,125 mm (10 mm increase since 16:00 on November 15)	—
	Water level of Turbine Building	O.P.+ 2,962 mm (9 mm increase since 16:00 on November 15)	O.P.+ 3,067 mm (30 mm decrease since 16:00 on November 15)	O.P.+ 3,045 mm (12 mm increase since 16:00 on November 15)	O.P.+ 3,002 mm (10 mm increase since 16:00 on November 15)
	Water level of Reactor Building	O.P.+ 4,455 mm (27 mm decrease since 16:00 on November 15)	O.P.+ 3,331 mm (33 mm decrease since 16:00 on November 15)	O.P.+ 3,214 mm (13 mm increase since 16:00 on November 15)	O.P.+ 3,003 mm (10 mm increase since 16:00 on November 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,248 mm (Increase from initial level:5,465 mm, 2 mm increase since 16:00 on November 15) O.P.+ 2,708 mm (Increase from initial level:3,434 mm, 58 mm decrease since 16:00 on November 15) O.P.+ 4,257 mm (Water level from floor:461 mm, No change since 16:00 on November 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:05 on November 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:18 on November 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:40 on November 15 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- From 5:10 PM on November 15 to 8:30 AM on November 16, transferring of accumulated water from the Common Pool Duct to the Central Radioactive Waste Treatment Facility (High Temperature Incinerator Building) was conducted.				

For quick publication of the data of water level, values are provided as reference values.