

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 16)**

Water Level of the accumulated water (at 16:00 on November 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,051 mm (19 mm increase since 7:00 on November 16)	O.P.+ 3,111 mm (14 mm decrease since 7:00 on November 16)	—
	Water level of Turbine Building	O.P.+ 2,967 mm (5 mm increase since 7:00 on November 16)	O.P.+ 3,084 mm (17 mm increase since 7:00 on November 16)	O.P.+ 3,025 mm (20 mm decrease since 7:00 on November 16)	O.P.+ 3,007 mm (5 mm increase since 7:00 on November 16)
	Water level of Reactor Building	O.P.+ 4,439 mm (16 mm decrease since 7:00 on November 16)	O.P.+ 3,330 mm (1 mm decrease since 7:00 on November 16)	O.P.+ 3,201 mm (13 mm decrease since 7:00 on November 16)	O.P.+ 3,008 mm (5 mm increase since 7:00 on November 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,251 mm (Increase from initial level:5,468 mm, 3 mm increase since 7:00 on November 16) O.P.+ 2,636 mm (Increase from initial level:3,362 mm, 72 mm decrease since 7:00 on November 16) O.P.+ 4,257 mm (Water level from floor:461 mm, No change since 7:00 on November 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 10:05 on November 11 to 9:43 on November 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:18 on November 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:40 on November 15 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.