

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 19)**

Water Level of the accumulated water (at 7:00 on November 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,113 mm (44 mm decrease since 16:00 on November 18)	O.P.+ 3,085 mm (14 mm increase since 16:00 on November 18)	—
	Water level of Turbine Building	O.P.+ 3,003 mm (7 mm increase since 16:00 on November 18)	O.P.+ 3,137 mm (38 mm decrease since 16:00 on November 18)	O.P.+ 2,998 mm (24 mm increase since 16:00 on November 18)	O.P.+ 2,974 mm (2 mm increase since 16:00 on November 18)
	Water level of Reactor Building	O.P.+ 4,453 mm (2 mm increase since 16:00 on November 18)	O.P.+ 3,399 mm (38 mm decrease since 16:00 on November 18)	O.P.+ 3,167 mm (28 mm increase since 16:00 on November 18)	O.P.+ 2,976 mm (1 mm decrease since 16:00 on November 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,263 mm (Increase from initial level:5,480 mm, 2 mm increase since 16:00 on November 18) O.P.+ 2,151 mm (Increase from initial level:2,877 mm, 113 mm decrease since 16:00 on November 18) O.P.+ 4,257 mm (Water level from floor:461 mm, No change since 16:00 on November 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:06 on November 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:18 on November 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:40 on November 15 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.