

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 19)**

Water Level of the accumulated water (at 16:00 on November 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,090 mm (23 mm decrease since 7:00 on November 19)	O.P.+ 3,090 mm (5 mm increase since 7:00 on November 19)	—
	Water level of Turbine Building	O.P.+ 3,009 mm (6 mm increase since 7:00 on November 19)	O.P.+ 3,116 mm (21 mm decrease since 7:00 on November 19)	O.P.+ 3,007 mm (9 mm increase since 7:00 on November 19)	O.P.+ 2,959 mm (15 mm decrease since 7:00 on November 19)
	Water level of Reactor Building	O.P.+ 4,450 mm (3 mm decrease since 7:00 on November 19)	O.P.+ 3,381 mm (18 mm decrease since 7:00 on November 19)	O.P.+ 3,177 mm (10 mm increase since 7:00 on November 19)	O.P.+ 2,967 mm (9 mm decrease since 7:00 on November 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,265 mm (Increase from initial level:5,482 mm, 2 mm increase since 7:00 on November 19) O.P.+ 2,214 mm (Increase from initial level:2,940 mm, 63 mm increase since 7:00 on November 19) O.P.+ 4,257 mm (Water level from floor:461 mm, No change since 7:00 on November 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:06 on November 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:18 on November 15)	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:02 on November 19)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:40 on November 15 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.