

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 20)**

Water Level of the accumulated water (at 7:00 on November 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,053 mm (37 mm decrease since 16:00 on November 19)	O.P.+ 3,092 mm (2 mm increase since 16:00 on November 19)	—
	Water level of Turbine Building	O.P.+ 3,017 mm (8 mm increase since 16:00 on November 19)	O.P.+ 3,084 mm (32 mm decrease since 16:00 on November 19)	O.P.+ 3,014 mm (7 mm increase since 16:00 on November 19)	O.P.+ 2,926 mm (33 mm decrease since 16:00 on November 19)
	Water level of Reactor Building	O.P.+ 4,442 mm (8 mm decrease since 16:00 on November 19)	O.P.+ 3,351 mm (30 mm decrease since 16:00 on November 19)	O.P.+ 3,186 mm (9 mm increase since 16:00 on November 19)	O.P.+ 2,935 mm (32 mm decrease since 16:00 on November 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,267 mm (Increase from initial level:5,484 mm, 2 mm increase since 16:00 on November 19) O.P.+ 2,424 mm (Increase from initial level:3,150 mm, 210 mm increase since 16:00 on November 19) O.P.+ 4,259 mm (Water level from floor:463 mm, 2 mm increase since 16:00 on November 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:06 on November 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:18 on November 15)	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:02 on November 19)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:26 on November 20 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Since a worker of TEPCO on patrol found a water leakage (of about pencil thickness) from the pipe which removes air from the adsorption tower of the 2nd Cesium Adsorption Apparatus (Sarry) to the outside of the High Temperature Incinerator Building at around 8:00 AM on November 20, we stopped the 2nd Cesium Adsorption Apparatus (Sarry) at around 8:26 AM.				

For quick publication of the data of water level, values are provided as reference values.