

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 20)**

Water Level of the accumulated water (at 16:00 on November 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,032 mm (21 mm decrease since 7:00 on November 20)	O.P.+ 3,103 mm (11 mm increase since 7:00 on November 20)	—
	Water level of Turbine Building	O.P.+ 3,022 mm (5 mm increase since 7:00 on November 20)	O.P.+ 3,065 mm (19 mm decrease since 7:00 on November 20)	O.P.+ 3,040 mm (26 mm increase since 7:00 on November 20)	O.P.+ 2,926 mm (No change since 7:00 on November 20)
	Water level of Reactor Building	O.P.+ 4,434 mm (8 mm decrease since 7:00 on November 20)	O.P.+ 3,332 mm (19 mm decrease since 7:00 on November 20)	O.P.+ 3,207 mm (21 mm increase since 7:00 on November 20)	O.P.+ 2,930 mm (5 mm decrease since 7:00 on November 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,269 mm (Increase from initial level:5,486 mm, 2 mm increase since 7:00 on November 20) O.P.+ 2,562 mm (Increase from initial level:3,288 mm, 138 mm increase since 7:00 on November 20) O.P.+ 4,259 mm (Water level from floor:463 mm, No change since 7:00 on November 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:06 on November 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:18 on November 15 to 10:30 on November 20)	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:02 on November 19 to 10:43 on November 20)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:26 on November 20 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- Transferring of the accumulated water was stopped due to the suspension of the second Cesium Adsorption Apparatus (SARRY) .				

For quick publication of the data of water level, values are provided as reference values.