

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 21)**

Water Level of the accumulated water (at 7:00 on November 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,997 mm (35 mm decrease since 16:00 on November 20)	O.P.+ 3,147 mm (44 mm increase since 16:00 on November 20)	—
	Water level of Turbine Building	O.P.+ 3,029 mm (7 mm increase since 16:00 on November 20)	O.P.+ 3,034 mm (31 mm decrease since 16:00 on November 20)	O.P.+ 3,096 mm (56 mm increase since 16:00 on November 20)	O.P.+ 2,949 mm (23 mm increase since 16:00 on November 20)
	Water level of Reactor Building	O.P.+ 4,415 mm (19 mm decrease since 16:00 on November 20)	O.P.+ 3,301 mm (31 mm decrease since 16:00 on November 20)	O.P.+ 3,266 mm (59 mm increase since 16:00 on November 20)	O.P.+ 2,950 mm (20 mm increase since 16:00 on November 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,271 mm (Increase from initial level:5,488 mm, 2 mm increase since 16:00 on November 20) O.P.+ 2,604 mm (Increase from initial level:3,330 mm, 42 mm increase since 16:00 on November 20) O.P.+ 4,258 mm (Water level from floor:462 mm, 1 mm decrease since 16:00 on November 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:06 on November 18)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:26 on November 20 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.