

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 21)**

Water Level of the accumulated water (at 16:00 on November 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,015 mm (18 mm increase since 7:00 on November 21)	O.P.+ 3,163 mm (16 mm increase since 7:00 on November 21)	—
	Water level of Turbine Building	O.P.+ 3,033 mm (4 mm increase since 7:00 on November 21)	O.P.+ 3,050 mm (16 mm increase since 7:00 on November 21)	O.P.+ 3,098 mm (2 mm increase since 7:00 on November 21)	O.P.+ 2,964 mm (15 mm increase since 7:00 on November 21)
	Water level of Reactor Building	O.P.+ 4,402 mm (13 mm decrease since 7:00 on November 21)	O.P.+ 3,297 mm (4 mm decrease since 7:00 on November 21)	O.P.+ 3,274 mm (8 mm increase since 7:00 on November 21)	O.P.+ 2,964 mm (14 mm increase since 7:00 on November 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,273 mm (Increase from initial level:5,490 mm, 2 mm increase since 7:00 on November 21) O.P.+ 2,642 mm (Increase from initial level:3,368 mm, 38 mm increase since 7:00 on November 21) O.P.+ 4,259 mm (Water level from floor:463 mm, 1 mm increase since 7:00 on November 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 10:06 on November 18 to 9:25 on November 21)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:26 on November 20   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.