

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 22)**

Water Level of the accumulated water (at 7:00 on November 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,060 mm (45 mm increase since 16:00 on November 21)	O.P.+ 3,162 mm (1 mm decrease since 16:00 on November 21)	—
	Water level of Turbine Building	O.P.+ 3,040 mm (7 mm increase since 16:00 on November 21)	O.P.+ 3,090 mm (40 mm increase since 16:00 on November 21)	O.P.+ 3,088 mm (10 mm decrease since 16:00 on November 21)	O.P.+ 2,987 mm (23 mm increase since 16:00 on November 21)
	Water level of Reactor Building	O.P.+ 4,388 mm (14 mm decrease since 16:00 on November 21)	O.P.+ 3,336 mm (39 mm increase since 16:00 on November 21)	O.P.+ 3,266 mm (8 mm decrease since 16:00 on November 21)	O.P.+ 2,982 mm (18 mm increase since 16:00 on November 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,275 mm (Increase from initial level:5,492 mm, 2 mm increase since 16:00 on November 21) O.P.+ 2,684 mm (Increase from initial level:3,410 mm, 42 mm increase since 16:00 on November 21) O.P.+ 4,259 mm (Water level from floor:463 mm, No change since 16:00 on November 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:26 on November 20 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.