

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 26)**

Water Level of the accumulated water (at 7:00 on November 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,230 mm (52 mm decrease since 16:00 on November 25)	O.P.+ 3,110 mm (14 mm increase since 16:00 on November 25)	—
	Water level of Turbine Building	O.P.+ 2,650 mm (8 mm increase since 16:00 on November 25)	O.P.+ 3,237 mm (45 mm decrease since 16:00 on November 25)	O.P.+ 3,022 mm (25 mm increase since 16:00 on November 25)	O.P.+ 2,995 mm (2 mm increase since 16:00 on November 25)
	Water level of Reactor Building	O.P.+ 4,390 mm (4 mm increase since 16:00 on November 25)	O.P.+ 3,501 mm (37 mm decrease since 16:00 on November 25)	O.P.+ 3,192 mm (28 mm increase since 16:00 on November 25)	O.P.+ 2,994 mm (3 mm decrease since 16:00 on November 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,292 mm (Increase from initial level:5,509 mm, 2 mm increase since 16:00 on November 25) O.P.+ 1,734 mm (Increase from initial level:2,460 mm, 100 mm decrease since 16:00 on November 25) O.P.+ 4,260 mm (Water level from floor:464 mm, 1 mm increase since 16:00 on November 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:14 on November 25)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:15 on November 23)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:57 on November 22 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.