

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 28)**

Water Level of the accumulated water (at 16:00 on November 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,073 mm (25 mm decrease since 7:00 on November 28)	O.P.+ 3,114 mm (2 mm decrease since 7:00 on November 28)	—
	Water level of Turbine Building	O.P.+ 2,675 mm (3 mm increase since 7:00 on November 28)	O.P.+ 3,101 mm (20 mm decrease since 7:00 on November 28)	O.P.+ 3,037 mm (1 mm decrease since 7:00 on November 28)	O.P.+ 2,882 mm (16 mm decrease since 7:00 on November 28)
	Water level of Reactor Building	O.P.+ 4,367 mm (7 mm decrease since 7:00 on November 28)	O.P.+ 3,368 mm (17 mm decrease since 7:00 on November 28)	O.P.+ 3,216 mm (No change since 7:00 on November 28)	O.P.+ 2,895 mm (14 mm decrease since 7:00 on November 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,302 mm (Increase from initial level:5,519 mm, 2 mm increase since 7:00 on November 28) O.P.+ 2,844 mm (Increase from initial level:3,570 mm, 175 mm increase since 7:00 on November 28) O.P.+ 4,259 mm (Water level from floor:463 mm, No change since 7:00 on November 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:14 on November 25)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:15 on November 23)	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:51 on November 26)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:33 on November 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.