

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on November 29)**

Water Level of the accumulated water (at 16:00 on November 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,014 mm (22 mm decrease since 7:00 on November 29)	O.P.+ 3,111 mm (No change since 7:00 on November 29)	—
	Water level of Turbine Building	O.P.+ 2,682 mm (3 mm increase since 7:00 on November 29)	O.P.+ 3,047 mm (20 mm decrease since 7:00 on November 29)	O.P.+ 3,038 mm (1 mm increase since 7:00 on November 29)	O.P.+ 2,863 mm (6 mm increase since 7:00 on November 29)
	Water level of Reactor Building	O.P.+ 4,357 mm (5 mm decrease since 7:00 on November 29)	O.P.+ 3,319 mm (18 mm decrease since 7:00 on November 29)	O.P.+ 3,213 mm (2 mm decrease since 7:00 on November 29)	O.P.+ 2,869 mm (2 mm decrease since 7:00 on November 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,305 mm (Increase from initial level:5,522 mm, No change since 7:00 on November 29) O.P.+ 3,266 mm (Increase from initial level:3,992 mm, 54 mm increase since 7:00 on November 29) O.P.+ 4,260 mm (Water level from floor:464 mm, No change since 7:00 on November 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:14 on November 25)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:15 on November 23)	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 9:51 on November 26 to 10:05 on November 29)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:33 on November 27   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.