

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on November 30)**

Water Level of the accumulated water (at 7:00 on November 30)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,978 mm (36 mm decrease since 16:00 on November 29)	O.P.+ 3,112 mm (1 mm increase since 16:00 on November 29)	—
	Water level of Turbine Building	O.P.+ 2,685 mm (3 mm increase since 16:00 on November 29)	O.P.+ 3,016 mm (31 mm decrease since 16:00 on November 29)	O.P.+ 3,037 mm (1 mm decrease since 16:00 on November 29)	O.P.+ 2,887 mm (24 mm increase since 16:00 on November 29)
	Water level of Reactor Building	O.P.+ 4,348 mm (9 mm decrease since 16:00 on November 29)	O.P.+ 3,288 mm (31 mm decrease since 16:00 on November 29)	O.P.+ 3,213 mm (No change since 16:00 on November 29)	O.P.+ 2,892 mm (23 mm increase since 16:00 on November 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,308 mm (Increase from initial level:5,525 mm, 3 mm increase since 16:00 on November 29) O.P.+ 3,207 mm (Increase from initial level:3,933 mm, 59 mm decrease since 16:00 on November 29) O.P.+ 4,260 mm (Water level from floor:464 mm, No change since 16:00 on November 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:14 on November 25)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:15 on November 23)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:32 on November 30 Suspended* Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- *: Due to the vessel replacement, transfer is stopped temporarily.				

For quick publication of the data of water level, values are provided as reference values.