

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 3)**

| | | | | | |
|---|--|---|--|---|--|
| Water Level of the accumulated water (at 7:00 on December 3) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 3,032 mm (39 mm increase since 16:00 on December 2) | O.P.+ 3,041 mm (15 mm decrease since 16:00 on December 2) | — |
| | Water level of Turbine Building | O.P.+ 2,706 mm (2 mm increase since 16:00 on December 2) | O.P.+ 3,061 mm (33 mm increase since 16:00 on December 2) | O.P.+ 2,916 mm (26 mm decrease since 16:00 on December 2) | O.P.+ 2,937 mm (12 mm decrease since 16:00 on December 2) |
| | Water level of Reactor Building | O.P.+ 4,309 mm (1 mm decrease since 16:00 on December 2) | O.P.+ 3,317 mm (34 mm increase since 16:00 on December 2) | O.P.+ 3,097 mm (29 mm decrease since 16:00 on December 2) | O.P.+ 2,943 mm (11 mm decrease since 16:00 on December 2) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 4,320 mm (Increase from initial level:5,537 mm, 3 mm increase since 16:00 on December 2) O.P.+ 3,201 mm (Increase from initial level:3,927 mm, 49 mm decrease since 16:00 on December 2) O.P.+ 4,260 mm (Water level from floor:464 mm, No change since 16:00 on December 2) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | — | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:15 on November 23) | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:15 on November 30 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | | | | | |

For quick publication of the data of water level, values are provided as reference values.