

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on December 3)**

Water Level of the accumulated water (at 16:00 on December 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,055 mm (23 mm increase since 7:00 on December 3)	O.P.+ 3,032 mm (9 mm decrease since 7:00 on December 3)	—
	Water level of Turbine Building	O.P.+ 2,709 mm (3 mm increase since 7:00 on December 3)	O.P.+ 3,080 mm (19 mm increase since 7:00 on December 3)	O.P.+ 2,904 mm (12 mm decrease since 7:00 on December 3)	O.P.+ 2,928 mm (9 mm decrease since 7:00 on December 3)
	Water level of Reactor Building	O.P.+ 4,313 mm (4 mm increase since 7:00 on December 3)	O.P.+ 3,338 mm (21 mm increase since 7:00 on December 3)	O.P.+ 3,083 mm (14 mm decrease since 7:00 on December 3)	O.P.+ 2,936 mm (7 mm decrease since 7:00 on December 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,322 mm (Increase from initial level:5,539 mm, 2 mm increase since 7:00 on December 3) O.P.+ 3,174 mm (Increase from initial level:3,900 mm, 27 mm decrease since 7:00 on December 3) O.P.+ 4,261 mm (Water level from floor:465 mm, 1 mm increase since 7:00 on December 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:15 on November 23)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:15 on November 30 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.