

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 4)**

| | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
|--|--|---|--|--|---|
| Water Level of the accumulated water (at 7:00 on December 4) | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 3,091 mm (36 mm increase since 16:00 on December 3) | O.P.+ 3,017 mm (15 mm decrease since 16:00 on December 3) | — |
| | Water level of Turbine Building | O.P.+ 2,712 mm (3 mm increase since 16:00 on December 3) | O.P.+ 3,112 mm (32 mm increase since 16:00 on December 3) | O.P.+ 2,883 mm (21 mm decrease since 16:00 on December 3) | O.P.+ 2,915 mm (13 mm decrease since 16:00 on December 3) |
| | Water level of Reactor Building | O.P.+ 4,323 mm (10 mm increase since 16:00 on December 3) | O.P.+ 3,373 mm (35 mm increase since 16:00 on December 3) | O.P.+ 3,063 mm (20 mm decrease since 16:00 on December 3) | O.P.+ 2,923 mm (13 mm decrease since 16:00 on December 3) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 4,330 mm (Increase from initial level:5,547 mm, 8 mm increase since 16:00 on December 3) O.P.+ 3,130 mm (Increase from initial level:3,856 mm, 44 mm decrease since 16:00 on December 3) O.P.+ 4,262 mm (Water level from floor:466 mm, 1 mm increase since 16:00 on December 3) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | — | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:15 on November 23) | — |
| | | Unit 5 and 6 | | | |
| | — | | | | |
| Operation condition of water treatment facility | Cesium Adsorption Apparatus: Since 9:00 on October 3 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:42 on December 4 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | | |
| Notes | - At 8:24 AM on December 4, we stopped the second Cesium Adsorption Apparatus (SARRY) due to replacement of the backup line of the accumulated water treatment line within the area using pressure hose for reliability improvement. | | | | |

For quick publication of the data of water level, values are provided as reference values.