

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 5)**

Water Level of the accumulated water (at 7:00 on December 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,151 mm (38 mm increase since 16:00 on December 4)	O.P.+ 2,992 mm (16 mm decrease since 16:00 on December 4)	—
	Water level of Turbine Building	O.P.+ 2,719 mm (5 mm increase since 16:00 on December 4)	O.P.+ 3,164 mm (32 mm increase since 16:00 on December 4)	O.P.+ 2,850 mm (21 mm decrease since 16:00 on December 4)	O.P.+ 2,891 mm (14 mm decrease since 16:00 on December 4)
	Water level of Reactor Building	O.P.+ 4,359 mm (20 mm increase since 16:00 on December 4)	O.P.+ 3,422 mm (25 mm increase since 16:00 on December 4)	O.P.+ 3,031 mm (21 mm decrease since 16:00 on December 4)	O.P.+ 2,900 mm (15 mm decrease since 16:00 on December 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,248 mm (Increase from initial level:5,465 mm, 70 mm decrease since 16:00 on December 4) O.P.+ 3,288 mm (Increase from initial level:4,014 mm, 61 mm increase since 16:00 on December 4) O.P.+ 4,263 mm (Water level from floor:467 mm, 1 mm increase since 16:00 on December 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:10 on December 4)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:38 on December 4 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:42 on December 4 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.