

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 6)**

Water Level of the accumulated water (at 7:00 on December 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,206 mm (34 mm increase since 16:00 on December 5)	O.P.+ 2,965 mm (16 mm decrease since 16:00 on December 5)	—
	Water level of Turbine Building	O.P.+ 2,723 mm (3 mm increase since 16:00 on December 5)	O.P.+ 3,210 mm (29 mm increase since 16:00 on December 5)	O.P.+ 2,818 mm (20 mm decrease since 16:00 on December 5)	O.P.+ 2,864 mm (17 mm decrease since 16:00 on December 5)
	Water level of Reactor Building	O.P.+ 4,379 mm (12 mm increase since 16:00 on December 5)	O.P.+ 3,471 mm (31 mm increase since 16:00 on December 5)	O.P.+ 2,999 mm (19 mm decrease since 16:00 on December 5)	O.P.+ 2,875 mm (15 mm decrease since 16:00 on December 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,145 mm (Increase from initial level:5,362 mm, 63 mm decrease since 16:00 on December 5) O.P.+ 3,381 mm (Increase from initial level:4,107 mm, 58 mm increase since 16:00 on December 5) O.P.+ 4,262 mm (Water level from floor:466 mm, No change since 16:00 on December 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 10:10 on December 4 to 8:14 on December 6)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:38 on December 4 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:42 on December 4 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.