Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on December 6)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on December 6)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,226 mm (20 mm increase since 7:00 on December 6)	O.P.+ 2,964 mm (1 mm decrease since 7:00 on December 6)	_
	Water level of Turbine Building	O.P.+ 2,726 mm (3 mm increase since 7:00 on December 6)	O.P.+ 3,228 mm (18 mm increase since 7:00 on December 6)	O.P.+ 2,842 mm (24 mm increase since 7:00 on December 6)	O.P.+ 2,856 mm (8 mm decrease since 7:00 on December 6)
	Water level of Reactor Building	O.P.+ 4,389 mm (10 mm increase since 7:00 on December 6)	O.P.+ 3,488 mm (17 mm increase since 7:00 on December 6)	O.P.+ 3,015 mm (16 mm increase since 7:00 on December 6)	O.P.+ 2,866 mm (9 mm decrease since 7:00 on December 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building	O.P.+ 4,002 mm (Increase from initial level:5,219 mm, 143 mm decrease since 7:00 on December 6)		
		High Temperature Incinerator Building	O.P.+ 3,445 mm (Increase from initial level:4,171 mm, 64 mm increase since 7:00 on December 6)		
		On-site Bunker Building	O.P.+ 4,263 mm (Water level from floor:467 mm, 1 mm increase since 7:00 on December 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		_	_	_	_
		Unit 5 and 6			
		_			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:38 on December 4 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:42 on December 4 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.