

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 7)**

Water Level of the accumulated water (at 7:00 on December 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,258 mm (32 mm increase since 16:00 on December 6)	O.P.+ 2,971 mm (7 mm increase since 16:00 on December 6)	—
	Water level of Turbine Building	O.P.+ 2,729 mm (3 mm increase since 16:00 on December 6)	O.P.+ 3,256 mm (28 mm increase since 16:00 on December 6)	O.P.+ 2,858 mm (16 mm increase since 16:00 on December 6)	O.P.+ 2,856 mm (No change since 16:00 on December 6)
	Water level of Reactor Building	O.P.+ 4,398 mm (9 mm increase since 16:00 on December 6)	O.P.+ 3,515 mm (27 mm increase since 16:00 on December 6)	O.P.+ 3,033 mm (18 mm increase since 16:00 on December 6)	O.P.+ 2,864 mm (2 mm decrease since 16:00 on December 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,732 mm (Increase from initial level:4,949 mm, 270 mm decrease since 16:00 on December 6) O.P.+ 3,559 mm (Increase from initial level:4,285 mm, 114 mm increase since 16:00 on December 6) O.P.+ 4,264 mm (Water level from floor:468 mm, 1 mm increase since 16:00 on December 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:38 on December 4 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:42 on December 4 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.