

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 10)**

Water Level of the accumulated water (at 7:00 on December 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,228 mm (37 mm decrease since 16:00 on December 9)	O.P.+ 2,986 mm (10 mm increase since 16:00 on December 9)	—
	Water level of Turbine Building	O.P.+ 2,744 mm (3 mm increase since 16:00 on December 9)	O.P.+ 3,229 mm (32 mm decrease since 16:00 on December 9)	O.P.+ 2,875 mm (13 mm increase since 16:00 on December 9)	O.P.+ 2,863 mm (10 mm increase since 16:00 on December 9)
	Water level of Reactor Building	O.P.+ 4,351 mm (19 mm decrease since 16:00 on December 9)	O.P.+ 3,490 mm (31 mm decrease since 16:00 on December 9)	O.P.+ 3,052 mm (14 mm increase since 16:00 on December 9)	O.P.+ 2,869 mm (9 mm increase since 16:00 on December 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,591 mm (Increase from initial level:4,808 mm, 3 mm increase since 16:00 on December 9) O.P.+ 3,407 mm (Increase from initial level:4,133 mm, 21 mm decrease since 16:00 on December 9) O.P.+ 4,266 mm (Water level from floor:470 mm, 1 mm increase since 16:00 on December 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:50 on December 8)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:00 on December 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:42 on December 7 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.