

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 11)**

Water Level of the accumulated water (at 7:00 on December 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,172 mm (36 mm decrease since 16:00 on December 10)	O.P.+ 3,001 mm (8 mm increase since 16:00 on December 10)	—
	Water level of Turbine Building	O.P.+ 2,752 mm (2 mm increase since 16:00 on December 10)	O.P.+ 3,180 mm (30 mm decrease since 16:00 on December 10)	O.P.+ 2,895 mm (12 mm increase since 16:00 on December 10)	O.P.+ 2,877 mm (9 mm increase since 16:00 on December 10)
	Water level of Reactor Building	O.P.+ 4,317 mm (23 mm decrease since 16:00 on December 10)	O.P.+ 3,441 mm (28 mm decrease since 16:00 on December 10)	O.P.+ 3,070 mm (9 mm increase since 16:00 on December 10)	O.P.+ 2,883 mm (9 mm increase since 16:00 on December 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,596 mm (Increase from initial level:4,813 mm, 1 mm increase since 16:00 on December 10) O.P.+ 3,384 mm (Increase from initial level:4,110 mm, 23 mm decrease since 16:00 on December 10) O.P.+ 4,267 mm (Water level from floor:471 mm, 1 mm increase since 16:00 on December 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:50 on December 8)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:00 on December 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:42 on December 7 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.