

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on December 11)**

Water Level of the accumulated water (at 16:00 on December 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,152 mm (20 mm decrease since 7:00 on December 11)	O.P.+ 3,009 mm (8 mm increase since 7:00 on December 11)	—
	Water level of Turbine Building	O.P.+ 2,754 mm (2 mm increase since 7:00 on December 11)	O.P.+ 3,162 mm (18 mm decrease since 7:00 on December 11)	O.P.+ 2,904 mm (9 mm increase since 7:00 on December 11)	O.P.+ 2,883 mm (6 mm increase since 7:00 on December 11)
	Water level of Reactor Building	O.P.+ 4,304 mm (13 mm decrease since 7:00 on December 11)	O.P.+ 3,421 mm (20 mm decrease since 7:00 on December 11)	O.P.+ 3,079 mm (9 mm increase since 7:00 on December 11)	O.P.+ 2,889 mm (6 mm increase since 7:00 on December 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,600 mm (Increase from initial level:4,817 mm, 4 mm increase since 7:00 on December 11) O.P.+ 3,378 mm (Increase from initial level:4,104 mm, 6 mm decrease since 7:00 on December 11) O.P.+ 4,267 mm (Water level from floor:471 mm, No change since 7:00 on December 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:50 on December 8)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:00 on December 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:42 on December 7   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.