

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 12)**

| | | | | | |
|--|---|--|---|--|--|
| Water Level of the accumulated water (at 7:00 on December 12) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 3,125 mm (27 mm decrease since 16:00 on December 11) | O.P.+ 3,016 mm (7 mm increase since 16:00 on December 11) | — |
| | Water level of Turbine Building | O.P.+ 2,757 mm (3 mm increase since 16:00 on December 11) | O.P.+ 3,138 mm (24 mm decrease since 16:00 on December 11) | O.P.+ 2,910 mm (6 mm increase since 16:00 on December 11) | O.P.+ 2,892 mm (9 mm increase since 16:00 on December 11) |
| | Water level of Reactor Building | O.P.+ 4,286 mm (18 mm decrease since 16:00 on December 11) | O.P.+ 3,400 mm (21 mm decrease since 16:00 on December 11) | O.P.+ 3,086 mm (7 mm increase since 16:00 on December 11) | O.P.+ 2,897 mm (8 mm increase since 16:00 on December 11) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 3,603 mm (Increase from initial level:4,820 mm, 3 mm increase since 16:00 on December 11) O.P.+ 3,358 mm (Increase from initial level:4,084 mm, 20 mm decrease since 16:00 on December 11) O.P.+ 4,267 mm (Water level from floor:471 mm, No change since 16:00 on December 11) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred *1 (Since 19:42 on December 11) | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:00 on December 7) | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:25 on December 12 Suspended *2 Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | *1 The accumulated water transfer from Unit 2 Turbine Building basement to Unit 3 Turbine Building basement was stopped at 6:20 PM on December 11 due to the investigation of the causes of filtrate water leakage which was found in the pathway on the west side of Unit 3 Turbine Building 1st floor on December 11. *2 At 7:25 AM on December 12, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. | | | | |

For quick publication of the data of water level, values are provided as reference values.