

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 13)**

Water Level of the accumulated water (at 7:00 on December 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,071 mm (35 mm decrease since 16:00 on December 12)	O.P.+ 3,032 mm (9 mm increase since 16:00 on December 12)	—
	Water level of Turbine Building	O.P.+ 2,760 mm (2 mm increase since 16:00 on December 12)	O.P.+ 3,091 mm (29 mm decrease since 16:00 on December 12)	O.P.+ 2,928 mm (9 mm increase since 16:00 on December 12)	O.P.+ 2,907 mm (10 mm increase since 16:00 on December 12)
	Water level of Reactor Building	O.P.+ 4,263 mm (14 mm decrease since 16:00 on December 12)	O.P.+ 3,355 mm (28 mm decrease since 16:00 on December 12)	O.P.+ 3,106 mm (12 mm increase since 16:00 on December 12)	O.P.+ 2,911 mm (8 mm increase since 16:00 on December 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,606 mm (Increase from initial level:4,823 mm, 2 mm increase since 16:00 on December 12) O.P.+ 3,760 mm (Increase from initial level:4,486 mm, 2 mm decrease since 16:00 on December 12) O.P.+ 4,267 mm (Water level from floor:471 mm, No change since 16:00 on December 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 19:42 on December 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:00 on December 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:05 on December 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.