

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on December 14)**

Water Level of the accumulated water (at 16:00 on December 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,000 mm (18 mm decrease since 7:00 on December 14)	O.P.+ 3,053 mm (4 mm increase since 7:00 on December 14)	—
	Water level of Turbine Building	O.P.+ 2,764 mm (1 mm increase since 7:00 on December 14)	O.P.+ 3,027 mm (18 mm decrease since 7:00 on December 14)	O.P.+ 2,951 mm (6 mm increase since 7:00 on December 14)	O.P.+ 2,928 mm (6 mm increase since 7:00 on December 14)
	Water level of Reactor Building	O.P.+ 4,229 mm (9 mm decrease since 7:00 on December 14)	O.P.+ 3,300 mm (12 mm decrease since 7:00 on December 14)	O.P.+ 3,130 mm (6 mm increase since 7:00 on December 14)	O.P.+ 2,932 mm (6 mm increase since 7:00 on December 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,613 mm (Increase from initial level:4,830 mm, 2 mm increase since 7:00 on December 14) O.P.+ 3,702 mm (Increase from initial level:4,428 mm, 14 mm decrease since 7:00 on December 14) O.P.+ 4,268 mm (Water level from floor:472 mm, No change since 7:00 on December 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 19:42 on December 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:00 on December 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:05 on December 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.