

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 17)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on December 17)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,981 mm (54 mm increase since 16:00 on December 16)	O.P.+ 3,093 mm (7 mm increase since 16:00 on December 16)	—
	Water level of Turbine Building	O.P.+ 2,773 mm (2 mm increase since 16:00 on December 16)	O.P.+ 3,011 mm (46 mm increase since 16:00 on December 16)	O.P.+ 2,993 mm (10 mm increase since 16:00 on December 16)	O.P.+ 2,969 mm (8 mm increase since 16:00 on December 16)
	Water level of Reactor Building	O.P.+ 4,157 mm (16 mm decrease since 16:00 on December 16)	O.P.+ 3,267 mm (42 mm increase since 16:00 on December 16)	O.P.+ 3,177 mm (10 mm increase since 16:00 on December 16)	O.P.+ 2,973 mm (9 mm increase since 16:00 on December 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,626 mm (Increase from initial level:4,843 mm, 3 mm increase since 16:00 on December 16) O.P.+ 3,029 mm (Increase from initial level:3,755 mm, 512 mm decrease since 16:00 on December 16) O.P.+ 4,271 mm (Water level from floor:475 mm, 1 mm increase since 16:00 on December 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:05 on December 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.