

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on December 17)**

Water Level of the accumulated water (at 16:00 on December 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,009 mm (28 mm increase since 7:00 on December 17)	O.P.+ 3,099 mm (6 mm increase since 7:00 on December 17)	—
	Water level of Turbine Building	O.P.+ 2,781 mm (8 mm increase since 7:00 on December 17)	O.P.+ 3,035 mm (24 mm increase since 7:00 on December 17)	O.P.+ 2,999 mm (6 mm increase since 7:00 on December 17)	O.P.+ 2,976 mm (7 mm increase since 7:00 on December 17)
	Water level of Reactor Building	O.P.+ 4,154 mm (3 mm decrease since 7:00 on December 17)	O.P.+ 3,291 mm (24 mm increase since 7:00 on December 17)	O.P.+ 3,184 mm (7 mm increase since 7:00 on December 17)	O.P.+ 2,977 mm (4 mm increase since 7:00 on December 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,627 mm (Increase from initial level:4,844 mm, 1 mm increase since 7:00 on December 17) O.P.+ 2,819 mm (Increase from initial level:3,545 mm, 210 mm decrease since 7:00 on December 17) O.P.+ 4,271 mm (Water level from floor:475 mm, No change since 7:00 on December 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:05 on December 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	– On November 22, we started transferring the accumulated water from the mega float to the temporary tank around Unit 5 and 6. At 4:55 PM on December 16, we completed transferring.				

※ For quick publication of the data of water level, values are provided as reference values.